

# Industrial Wastewater Pretreatment Monitoring Report

## Sampling Point #2 (Part 1, A&B)

Milbank Mfg

Year 01 Month MARCH

Date	Flow	pH	Cd	Cr	Cu	Ni	Ag	Pb	Zn	Mo	TTO	Phenol	CN	TPH	FOG	NH3	CBOD	COD	TSS
1	2960	9.60																	
2																			
3																			
4																			
5	1170	9.70																	
6	2670	9.66																	
7	2470	9.68																	
8	2640	9.62							4.020	4.020						1.7	66	670	64
9																			
10																			
11																			
12	2790	9.69																	
13	2910	9.73																	
14	2790	9.69																	
15																			
16																			
17																			
18																			
19																			
20																			
21	2790	9.74																	
22	2330	9.71																	
23																			
24																			
25																			
26	2330	9.59																	
27																			
28																			
29	1410	9.59																	
30																			
31																			
Daily LIMIT	N/A	N/A	.02	2.0	.6	.8	.24	.1	1.25	N/A	2.13	.5	.5	N/A	100	N/A	N/A	N/A	N/A
Average	2435	9.66							4.020	4.020						1.7	66	670	64
Maximum	2960	9.74							4.020	4.020						1.7	66	670	64
Minimum	1170	9.54							4.020	4.020						1.7	66	670	64

Total Flow 89,250

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Richard Tyler  
Authorized Company Representative

DATE 04-12-01

MIL0003641